

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  105147	(X2) MULTIPLE CONSTRUCTION A. Building B. Wing	(X3) DATE SURVEY COMPLETED  04/30/2026
NAME OF PROVIDER OR SUPPLIER  Pines of Sarasota		STREET ADDRESS, CITY, STATE, ZIP CODE  1501 N Orange Ave Sarasota, FL 34236	
For information on the nursing home's plan to correct this deficiency, please contact the nursing home or the state survey agency.			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (Each deficiency must be preceded by full regulatory or LSC identifying information)		
<p>F 0695</p> <p>Level of Harm - Minimal harm or potential for actual harm</p> <p>Residents Affected - Few</p>	<p>Provide safe and appropriate respiratory care for a resident when needed.</p> <p>Based on observations and interviews, the facility failed to ensure the safe storage of oxygen cylinders in 1 (West 1) of 4 units observed. The findings included: On 4/29/26 at 9:03 a.m., observation of the [NAME] 1 unit revealed 4 unsecured oxygen cylinders stored directly on the ground, not in the secured oxygen cylinder storage rack. The sign above the oxygen canisters read FULL OXYGEN CYLINDERS. Photographic evidence obtained. On 4/29/26 at 9:18 a.m., the Assistant Director of Nursing (ADON) verified the observation of the 4 cylinders of oxygen stored unsecured, directly on the ground. In an interview, the ADON verified that the oxygen cylinders were full and said they should not be stored on the ground. Review of the NFPA99 (2021) edition, 11.6.2.3 (11) revealed that, Cylinders shall be protected from damage by means of the following specific procedures: Oxygen cylinders shall be protected from abnormal mechanical shock, which is liable to damage the cylinder, valve, or safety device. Freestanding cylinders shall be properly chained or supported in a proper cylinder stand or cart. On 4/30/26 at 11:27 a.m., in an interview, the Director of Nursing (DON) said oxygen cylinders should be stored in a secure rack. The DON said oxygen cylinders should never be stored directly on the ground. The DON said oxygen cylinders stored unsecured on the floor were a safety risk. On 4/30/26 at 11:50 a.m., in an interview, the Maintenance Director said that oxygen cylinders should be in a secure rack and never stored directly on the ground. The Maintenance Director said oxygen cylinders that are stored directly on the floor can fall over and do some damage.</p>		

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------