

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  365831	(X2) MULTIPLE CONSTRUCTION A. Building B. Wing	(X3) DATE SURVEY COMPLETED  07/10/2024
NAME OF PROVIDER OR SUPPLIER  Danridges Burgundi Manor		STREET ADDRESS, CITY, STATE, ZIP CODE  31 Maranatha Drive Youngstown, OH 44505	

For information on the nursing home's plan to correct this deficiency, please contact the nursing home or the state survey agency.

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (Each deficiency must be preceded by full regulatory or LSC identifying information)
<p>F 0921</p> <p>Level of Harm - Minimal harm or potential for actual harm</p> <p>Residents Affected - Many</p>	<p>Make sure that the nursing home area is safe, easy to use, clean and comfortable for residents, staff and the public.</p> <p>44810</p> <p>Based on observation and interview the facility failed to maintain an outside sidewalk to allow for safe passage of residents. This had the potential to affect all residents residing in the facility. The facility census was 49.</p> <p>Findings include:</p> <p>Interview on 07/08/24 at 8:55 A.M. with Residents #24, #27, and #32 while they were out on the patio smoking confirmed they get their wheelchairs stuck in the large cracks in the sidewalks all the time. They also confirmed that the large divots on the sides of the sidewalk had wheelchair marks from where they rolled off the sidewalk and got stuck.</p> <p>Observation during the interview revealed the sidewalk to the smoking area had four cracks in sidewalks measuring six inches wide and two to three inches deep. There were numerous divots on the grass area next to the sidewalks measuring four to twelve inches deep with wheelchair marks where they got stuck.</p> <p>Interview and observation on 07/08/24 at 2:00 P.M. with the Director of Nursing (DON) confirmed the large cracks in the sidewalk leading to the smoking patio. He also confirmed the areas next to the sidewalks with large divots with wheelchair tire marks in them. He reported thankfully no one has been hurt out here.</p> <p>Interview on 07/08/24 at 2:25 P.M. with Maintenance Supervisor #555 confirmed there are a lot of big cracks in the sidewalk leading to the outside patio. He reported in the past staff have filled in the divots with hay and used quick concrete to fill them in, but it does not last, and residents get stuck in them.</p> <p>Interview on 07/09/24 at 1:40 P.M. with Resident #5, Resident #8, and Resident #34 confirmed they got stuck in the cracks in the sidewalk leading to the patio all the time. They confirmed they have not fallen but they get stuck, and it is hard especially with limited mobility and a bigger size. They reported no other concerns with their care.</p> <p>Interview on 07/09/24 at 1:45 P.M. with State tested Nursing Assistant (STNA) #530 confirmed the cracks in the sidewalk are extremely hard to push resident's wheelchairs over safely. She confirmed no injuries had happened that she is aware of, but it was not safe.</p>

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------