

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  375334	(X2) MULTIPLE CONSTRUCTION A. Building B. Wing	(X3) DATE SURVEY COMPLETED  08/06/2024
NAME OF PROVIDER OR SUPPLIER  Shady Rest Care Center		STREET ADDRESS, CITY, STATE, ZIP CODE  210 South Adair Pryor, OK 74361	
For information on the nursing home's plan to correct this deficiency, please contact the nursing home or the state survey agency.			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (Each deficiency must be preceded by full regulatory or LSC identifying information)		
<p>F 0584</p> <p>Level of Harm - Minimal harm or potential for actual harm</p> <p>Residents Affected - Some</p>	<p>Honor the resident's right to a safe, clean, comfortable and homelike environment, including but not limited to receiving treatment and supports for daily living safely.</p> <p>34270</p> <p>Based on observation, record review, and interview, the facility failed to provide comfortable room temperatures for two (#6 and #7) of four sampled residents reviewed for environment.</p> <p>A facility resident roster, dated 08/05/24, documented 37 residents resided at the facility.</p> <p>Findings:</p> <p>A facility indoor temperature policy, dated 05/23/24, documented indoor temperatures at the facility would be maintained between 72 degrees Fahrenheit and 80 degrees Fahrenheit.</p> <p>1. Resident #6 had diagnoses which included chronic kidney disease and obesity with alveolar hypoventilation (decreased oxygen levels and increased carbon dioxide levels).</p> <p>2. Resident #7 had diagnoses which included chronic obstructive pulmonary disease and congestive heart failure.</p> <p>On 08/05/24 at 1:52 p.m., Resident #7 stated the temperature in their room made her miserable and had been too hot for at least one month. The temperature in the room was measured by the surveyor and found to be 86.1 degrees Fahrenheit. The resident stated they had informed the administrator and other staff many times but the heat in their room had continued.</p> <p>On 08/05/24 at 1:55 p.m., Resident #6 stated the temperature in their room was too hot. The room temperature was measured by the surveyor and found to be 88.5 degrees Fahrenheit. The resident stated their room had been too hot for about one month. They stated they had informed the administrator and other staff members of the heat many times.</p> <p>On 08/06/24 at 12:04 p.m., CNA #2 stated the hallway and rooms where Residents #6 and #7 reside had been hot for about one month. They stated they were not sure if the administrator was aware of the situation.</p> <p>On 08/06/24 at 12:16 p.m., CNA #3 stated the area of the facility where Residents #6 and #7 reside have been very hot for about three months. They stated they had reported the situation to the administrator several times in those months.</p> <p>(continued on next page)</p>		

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  375334	(X2) MULTIPLE CONSTRUCTION A. Building B. Wing	(X3) DATE SURVEY COMPLETED  08/06/2024
NAME OF PROVIDER OR SUPPLIER  Shady Rest Care Center		STREET ADDRESS, CITY, STATE, ZIP CODE  210 South Adair Pryor, OK 74361	
For information on the nursing home's plan to correct this deficiency, please contact the nursing home or the state survey agency.			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (Each deficiency must be preceded by full regulatory or LSC identifying information)		
<p>F 0584</p> <p>Level of Harm - Minimal harm or potential for actual harm</p> <p>Residents Affected - Some</p>	<p>On 08/06/24 at 12:46 p.m., CNA #4 stated the rooms and hallway were Resident #6 and #7 reside have been very hot on and off for about one month. They were unsure if the administration had been informed.</p> <p>On 08/06/24 at 1:20 p.m., the Administrator stated they had been informed of the ineffective air conditioning the past Thursday [08/01/24] and had arranged for contractors to work on the air conditioning system. They stated the system was replaced on 08/05/24. They stated they were unaware that part of the building was having problems, and no one reported the issue to them until 08/01/24.</p>		