

Department of Health & Human Services
Centers for Medicare & Medicaid Services

Printed: 08/27/2026
Form Approved OMB
No. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 395471	(X2) MULTIPLE CONSTRUCTION A. Building B. Wing	(X3) DATE SURVEY COMPLETED 06/11/2026
NAME OF PROVIDER OR SUPPLIER Armstrong Rehabilitation and Nursing Center		STREET ADDRESS, CITY, STATE, ZIP CODE 265 South McKean Street Kittanning, PA 16201	
For information on the nursing home's plan to correct this deficiency, please contact the nursing home or the state survey agency.			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (Each deficiency must be preceded by full regulatory or LSC identifying information)		
F 0584 Level of Harm - Minimal harm or potential for actual harm Residents Affected - Some	Honor the resident's right to a safe, clean, comfortable and homelike environment, including but not limited to receiving treatment and supports for daily living safely. Based on review of facility policy, facility records, observations, and resident and staff interviews, it was determined that the facility failed to ensure comfortable room temperature levels were provided for eight out of 22 sampled residents (Residents R1, R2, R3, R4, R5, R6, R7, and Resident R8). Findings Include: Review of the facility policy Safe and Homelike Environment, dated 4/27/26, indicated in accordance with residents' rights, the facility will provide a safe, clean, comfortable and homelike environment, allowing the resident to use his or her personal belongings to the extent possible. The facility will maintain comfortable and safe temperature levels. The facility should strive to keep the temperature in common resident areas between 71 and 81 degrees Fahrenheit. Review of Room temperature audits dated 6/10/26, indicated 21 resident rooms temperatures were over 80 degrees Fahrenheit. Room temperature logs dated 6/11/26, indicated five resident rooms over 79 degrees Fahrenheit. Review of service provider repair proposal dated 6/10/26, indicated air conditioning repair estimate was completed, total repair costs were \$13,900, and the proposal was not signed yet by the facility ownership. Review of resident council minutes from May 2026 identified concerns with air conditioning units needing repair. During observations of the 200-nursing unit with Maintenance Supervisor Employee E1, room temperatures were taken at 10:20 a.m. Room temperatures over 79 degrees were found. All temperatures were in Fahrenheit and were as follows: Resident R1's room: 82 degrees Resident R2's room: 80 degrees Resident R3's room: 82 degrees Resident R4's room: 80 degrees During observations of the 300-nursing unit with Maintenance Supervisor Employee E1, room temperatures were taken at 10:26 a.m. Room temperatures over 79 degrees were found. All temperatures were in Fahrenheit and were as follows: Resident R5's room: 80 degrees Resident R6's room: 82 degrees Resident R7's room: 80 degrees Resident R8's room: 81 degrees During an interview on 6/11/26, at 11:48 a.m. Resident R10 was asked about his room temperature and he stated: I can tell you-it's hot. Was hot all day yesterday. Would like some air conditioning that works. During an interview on 6/11/26, at 11:51 a.m. Resident R2 was asked about the temperature in her room and she stated: I am hot. Been for a while. Not sure how long. During an interview on 6/11/26, at 11:53 a.m. Resident R1 stated I am hot. Been hot for one week. Got my own personal fan. During an interview on 6/11/26, at 11:57 a.m. Registered Nurse (RN) Employee E2 was asked about the room temperatures in the facility: I was here on Sunday. No issues on that day. Some of the resident today said it was hot. During an interview on 6/11/26, at 12:01 p.m. Resident R9 was asked about the temperature in the facility and stated: The air conditioning in my room is good now. A couple of days ago, it was 85 degrees in here. This happened last year. Air conditioning was out. I think the residents should have been notified if they have a bad part; they should tell us. During an interview on 6/11/26, at 12:17 p.m. Licensed Practical Nurse (LPN) Employee E3 was asked about the room temperatures in the facility and stated: Its better today; It was really hot yesterday. During an interview on 6/11/26, at 1:26 p.m. Social Services Employee E4 was asked if any residents complained about room temperatures before the 6/11/26: yes, resident council did. Additional observations of the 200-nursing unit with Maintenance Supervisor Employee E1, room temperatures were taken at 1:58 p.m. Room temperatures over 79 degrees were found. All temperatures were in (continued on next page)		

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
--	-------	-----------

Department of Health & Human Services
Centers for Medicare & Medicaid Services

Printed: 08/27/2026
Form Approved OMB
No. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 395471	(X2) MULTIPLE CONSTRUCTION A. Building B. Wing	(X3) DATE SURVEY COMPLETED 06/11/2026
NAME OF PROVIDER OR SUPPLIER Armstrong Rehabilitation and Nursing Center		STREET ADDRESS, CITY, STATE, ZIP CODE 265 South McKean Street Kittanning, PA 16201	
For information on the nursing home's plan to correct this deficiency, please contact the nursing home or the state survey agency.			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (Each deficiency must be preceded by full regulatory or LSC identifying information)		
F 0584 Level of Harm - Minimal harm or potential for actual harm Residents Affected - Some	Fahrenheit and were as follows:Resident R1's room: 80 degreesResident R3's room: 80 degreesResident R4's room: 80 degrees Additional observations of the 300-nursing unit tour with Maintenance Supervisor Employee E1, room temperatures were taken at 2:03 p.m. Room temperatures over 79 degrees were found. All temperatures were in Fahrenheit and were as follows:Resident R5's room: 80 degreesResident R6's room: 82 degreesResident R7's room: 80 degrees During an interview on 6/11/26, at 2:12 p.m. in Maintenance Supervisor Employee E1 confirmed that some residents' rooms were still over 80 degrees Fahrenheit. During an interview on 6/11/26, at 2:55 p.m. information disseminated to Director of Nursing (DON) and Social services Employee E4 that the facility failed to ensure comfortable room temperature levels were provided for Residents R1, R2, R3, R4, R5, R6, R7, and Resident R8 as required. 28 Pa. code: 201.14 (a) Responsibility of licensee. 28 Pa Code: 201.18 (e)(1)(2) Management. 28 Pa Code: 201.29 (a)(c)(d) Resident Rights		