

| | | | |
|---|--|--|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 455563 | (X2) MULTIPLE CONSTRUCTION A. Building B. Wing | (X3) DATE SURVEY COMPLETED 06/09/2025 |
| NAME OF PROVIDER OR SUPPLIER Denison Nursing and Rehab | | STREET ADDRESS, CITY, STATE, ZIP CODE 601 E Hwy 69 Denison, TX 75021 | |

For information on the nursing home's plan to correct this deficiency, please contact the nursing home or the state survey agency.

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (Each deficiency must be preceded by full regulatory or LSC identifying information) |
|--|---|
| <p>F 0921</p> <p>Level of Harm - Minimal harm or potential for actual harm</p> <p>Residents Affected - Few</p> | <p>Make sure that the nursing home area is safe, easy to use, clean and comfortable for residents, staff and the public.</p> <p>Based on observation, interview and record review, the facility failed to provide a safe environment for residents, staff, and the public for one (oxygen room) of one oxygen room and one (CNA room) of one CNA room observed for oxygen storage safety.</p> <p>The facility failed to securely store oxygen cylinders in the facility's only oxygen room and only CNA room on 06/06/25.</p> <p>These failures could affect the residents by placing them at risk of injury due to oxygen cylinders becoming unsecured and becoming a hazard.</p> <p>Findings included:</p> <p>Observation on 06/06/25 at 7:33 AM revealed one free-standing oxygen cylinder without a rack, chain, or strap in the corner of the CNA room by the door.</p> <p>Observation and interview on 06/06/25 at 7:35 AM with LVN A revealed the oxygen cylinder in the CNA room was unsecured. LVN A stated the oxygen cylinder should be secured in a rack. LVN A stated it was a safety risk for them to be unsecured.</p> <p>Observation and interview on 06/06/25 at 10:40 AM with the ADM revealed four free-standing oxygen cylinders without a rack, chain, or strap in the oxygen room. The ADM stated she did not know why the oxygen cylinders were not in the rack since there was room in the rack for them. The ADM stated the oxygen cylinder should be secured with a rack, bag or strap to prevent them from falling over since they were combustible.</p> <p>Interview on 06/09/25 at 9:08 AM with the ADM revealed the facility did not have a policy on oxygen storage.</p> <p>Review of National Fire Protective Association, (NFPA) 99, 2012 Edition, Section 11.6.2.3, reflected: .(11) Freestanding cylinders shall be properly chained or supported in a proper cylinder stand or cart .</p> |

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

| | | |
|---|-------|-----------|
| LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE |
|---|-------|-----------|